



# GARRETT COUNTY

## OFFICE OF THE FIRE MARSHAL



### *Information Bulletin*

#### **Impact Protection**

The following information is offered as acceptable impact protection per NFPA 1 (2018). Vehicle impact protection may be required around such items as propane storage, fuel tanks, fuel pumps, generators, or other sensitive equipment.

**General.** Vehicle impact protection required by this code shall be provided by posts that comply with Section 60.5.1.9 or by other approved physical barriers that comply with this Section .

**Posts.** Guard posts shall comply with all of the following requirements:

1. Constructed of steel not less than 4 inches (102 mm) in diameter and concrete filled.
2. Spaced not more than 4 feet (1219 mm) between posts on center.
3. Set not less than 3 feet (914 mm) deep in a concrete footing of not less than a 15-inch (381 mm) diameter.
4. Set with the top of the posts not less than 3 feet (914 mm) above ground.
5. Located not less than 3 feet (914 mm) from the protected object.

**Other barriers.** Barriers, other than posts specified in section 60.5.1.9.2, that are designed to resist, deflect, or visually deter vehicular impact commensurate with an anticipated impact scenario shall be permitted where approved.

Please contact the Garrett County Fire Marshal's Office at 301-334-5400 for further information.