

Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550

Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcounty.org

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett	
Is this a combined sewer overflow (CSO)	YES <input checked="" type="radio"/> NO <input type="radio"/> (CIRCLE ONE)	
When did the Overflow Occur	DATE: June 17, 2016	TIME: 6:00 <input checked="" type="radio"/> AM <input type="radio"/> PM
Is the Overflow Ongoing or has it been repaired	ONGOING <input checked="" type="radio"/> REPAIRED <input type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: 6:00 am - 2:15 pm 8 hrs; 15 min.
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	Culvert Crossing near 390 Glendale Spur rd. just off Glendale rd.	
Cause of the Overflow - Get as much information as possible.	Heavy rain overnight washed out road way and pipe cover, causing a crack in the 6" sewer main.	
What has been done to correct the Cause of the Overflow	damaged section of pipe has been replaced, pipe bedding & cover is being restored	
Did any of the Overflow Waste Water enter Waters of the State (Includes storm drains)	YES <input checked="" type="radio"/> NO <input type="radio"/> (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES)
Has/will the public be notified? If yes, how?	Un-named tributary and Deep Creek lake Yes Door to Door in affected area, and DNR placed Buys in the Cove, Press release to Follow at later time	
Has/will the affected water body be posted as being contaminated?	posted signs at every dock from Silver Tree Marina ground cove to Arrowhead Condos	
Estimated Quantity of the Overflow in GALLONS	6,300 gallon	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	Spill flowed directly into stream, no way to extract it.	
Name of the Person Reporting the Overflow	NAME: John Mic. Miller	PHONE: 301-501-1109
	TITLE: Superintendent	
Name and type of Facility	FACILITY NAME: Deep Creek lake	TYPE OF FACILITY: W.W.T.P. Collections
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN # CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)	
Name of Staff Receiving Report	Mark Deall	
Date and Time of Report	DATE: 6/17/16	TIME: 5:37 <input checked="" type="radio"/> AM <input type="radio"/> PM
Name of Staff Report was referred to for follow-up		
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; Inspector	

Steve Sherard from Garrett County Health Dept. and Seth Metheny from Natural Resources met me on site.