

Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550

Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcountry.org

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett	
Is this a combined sewer overflow (CSO)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	
When did the Overflow Occur	DATE: May 11, 2015	TIME: 2:29 pm AM/PM <input checked="" type="radio"/>
Is the Overflow Ongoing or has it been repaired	ONGOING <input type="radio"/> REPAIRED <input checked="" type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: 31 minutes
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	1188 Mt. View drive, Mt. Side development Oakland Md. 21550	
Cause of the Overflow - Get as much information as possible.	Contractor Hit 2" sewer main while installing a 3/4" water service	
What has been done to correct the Cause of the Overflow	Replaced damaged section of 2" sewer main	
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES)
Has/will the public be notified? If yes, how?	No	
Has/will the affected water body be posted as being contaminated?	N/A	
Estimated Quantity of the Overflow in GALLONS	1,000 gallons	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	leaking sewer was captured in a ditch, and reclaimed by vacuum truck. ditch was lime stabilized after clean up.	
Name of the Person Reporting the Overflow	NAME: John M.C. Miller TITLE: Superintendent	PHONE: 301 501 1109
Name and type of Facility	FACILITY NAME: Deep Creek Lake	TYPE OF FACILITY: Collections
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN 5 CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)	
Name of Staff Receiving Report	Mat Hogany	
Date and Time of Report	DATE: 5/12/15	TIME: 12:20 AM/PM <input checked="" type="radio"/>
Name of Staff Report was referred to for follow-up		
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; inspector	

* left message with Steve Sherrard Garrett Co. Health Dept 5/12/15 @ 11:25 pm