

Garrett County
Department of Financial Services
Purchasing Division
313 East Alder Street – Room 104
Oakland, Maryland 21550
301.334.1995 Fax 301.334.1985
purchasing@garrettcountry.org



Brian E. Bowers
Purchasing Agent
bbowers@garrettcountry.org

A D D E N D U M 1

DATE: September 19, 2023
TO: All Bidders
FROM: Brian Bowers
Purchasing Agent
RE: Invitation to Bid #23-0928
Garrett County Airport Terminal Roof Project

Please note the following clarification to Invitation to Bid #23-0928 Garrett County Airport Terminal Roof Project resulting from a question received from an interested Contractor:

1. On the specification sheet #5 under the description of work states "Install Cougar Guard Insulation." Can you provide a link and specification sheet for the material requested? I was unable to locate any information on this product nor have I heard of it.

Answer: Attached is a specification sheet for the Cougar Guard Insulation. An insulation substitution will be considered as long as the substitute product meets or exceeds the Cougar Guard Insulation specifications. If Contractor is bidding a substitute, please include a specification sheet for the insulation being bid with your bid submittal.

Please acknowledge receipt of Addendum 1 by initialing the appropriate section on the Signature to Bids Page of the bid package.

**New
Product!**

Cougars Shield - Cougars Tough!

Very Strong Product / Literally won't tear!!

**Made in
the USA**

- Has UV Protection
- Class A Fire Rating
- 10 Year Warranty
- 1 mil reflective metalized film
- 1/8" Closed cell foam
- 60 gsm white woven poly propylene scrim

For condensation control and a radiant barrier on the following:

- Post frame buildings
- Metal reroofing
- Steel buildings
- Agricultural buildings
- Storage facilities
- Confinement Buildings
- Garages & mini barns



6' x 125' roll

9 rolls / pallet
342 rolls / truckload

Technical Data

- ASTM G154 2000 hour UV exposure
- ISO 21898 UV exposure
- ASTM E84 flame spread
- ASTM C1224 Delamination and Piability
- ASTM F1306 Puncture and D882 Tensile strength

**Northern Building
Components**

44815 CR 388 Bloomingdale, MI 49026

(269)521-4554 ext. 1