

Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550
 Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcountry.org

COPY

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett	
Is this a combined sewer overflow (CSO)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	
When did the Overflow Occur	DATE: 1/31/14	TIME 6:30 AM <input checked="" type="radio"/> PM
Is the Overflow Ongoing or has it been repaired	ONGOING <input type="radio"/> REPAIRED <input checked="" type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: 2 hrs 6:30 ^{pm} - 8:30 ^{pm}
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	Marsh Hill rd, leaked out of Valve box in front of Deep Creek Trail	
Cause of the Overflow - Get as much information as possible.	Broken 4" sewer lateral	
What has been done to correct the Cause of the Overflow	Valve was shut off to 4" lateral, stopped leak Will be repaired Monday 2/3/14	
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	YES <input checked="" type="radio"/> NO <input type="radio"/> (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES) un named Small tributary stream to DCL
Has/will the public be notified? If yes, how?	Signs Posted in spill area & taped off	
Has/will the affected water body be posted as being contaminated?	Signs Posted in spill area & taped off	
Estimated Quantity of the Overflow in GALLONS	9,600 gal	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	Cleaned area with vacuum truck, lime stabilization & started sampling stream in AM of 2/1/14 for Ecoli	
Name of the Person Reporting the Overflow	NAME: John M.C. Miller TITLE: Superintendent	PHONE: (301) 387-9175 cell (301) 501-1109
Name and type of Facility	FACILITY NAME: Deep Creek lake	TYPE OF FACILITY: Collection
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN 5 CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)	
Name of Staff Receiving Report	Chuck Webster	
Date and Time of Report	DATE: 2/1/14	TIME: 11:34 AM <input checked="" type="radio"/> PM
Name of Staff Report was referred to for follow-up	Randy Denny 443-496-9507 @ 11:46 ^{am}	
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; inspector	

Called Steve Sherrard @ 7:54^{am} informed him of spill & got clean up & sampling directions