

Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550
 Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcountry.org

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett	
Is this a combined sewer overflow (CSO)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	
When did the Overflow Occur	DATE: 1-12-17	TIME 10:50 <input checked="" type="radio"/> AM <input type="radio"/> PM
Is the Overflow Ongoing or has it been repaired	ONGOING <input type="radio"/> REPAIRED <input checked="" type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: 63 minutes
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	308 Lake Forest Dr, Oakland, MD	
Cause of the Overflow - Get as much information as possible.	Failed check valve at main connection tap. Discharge piping busted inside grinder basin allowing P.S. main to backflow into basin causing overflow	
What has been done to correct the Cause of the Overflow	replaced check valve & repaired piping inside grinder basin	
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	<input checked="" type="radio"/> YES <input type="radio"/> NO (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES) Deep Creek Lake
Has/will the public be notified? If yes, how?	Neighboring property owners only - by letter	
Has/will the affected water body be posted as being contaminated?	yes	
Estimated Quantity of the Overflow in GALLONS	1,890	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	used tanker truck to vacuum standing water & spread with lime	
Name of the Person Reporting the Overflow	NAME: Brian King TITLE: Assistant Div. Chief, Maintenance	PHONE: 301-616-4168
Name and type of Facility	FACILITY NAME: Deep Creek Lake	TYPE OF FACILITY: WWTP
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN 5 CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)	
Name of Staff Receiving Report	Heidi Slagle	
Date and Time of Report	DATE: 1/12/17	TIME: 3:15 AM <input checked="" type="radio"/> PM <input type="radio"/>
Name of Staff Report was referred to for follow-up	Scott Boylan, Frostburg office	
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; inspector	